

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

**OFFICE USE ONLY**

Log No. 92532  
 Permit No. \_\_\_\_\_  
 Basin 8-102

NOTICE OF INTENT NO. 18592

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Jim Bashi ADDRESS AT WELL LOCATION SAME  
 MAILING ADDRESS 1285 E 6th St. Silver Springs, NV 89429  
 2. LOCATION SE 1/4 NW 1/4 Sec. 18 T. 17 N. S. R. 25 E County \_\_\_\_\_  
 PERMIT NO. 17-274-01 Parcel No. \_\_\_\_\_ Subdivision Name Tyler Sub #1  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Surface Soil		0	4	4
Fine Brown sand		4	17	13
Fine to coarse brown sand		17	40	23
Fine to coarse gray sand		40	115	75
gray clay		115	120	5
coarse sand + gravel	X	120	150	30

'93 AUG 30 P2:47  
 STATE ENGINEERS

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11' Inches To 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>150</u>

Perforations:  
 Type perforation Mill  
 Size perforation 3/32 x 3  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 150 feet

9. WATER LEVEL  
 Static water level 37 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ACE Drilling + Development Contractor  
 Address P.O. Box 668 Silver Springs, NV 89429 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 14299  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726  
 Signed H.L. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-20-93

Date started 8-18 1993  
 Date completed 8-20 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>3</u>	<u>2 hrs.</u>