

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 42540
 Permit No. 8-102
 Basin. 8

NOTICE OF INTENT NO. 19/38

1. OWNER Claude King ADDRESS AT WELL LOCATION 1535 E Deer St Silver Springs NV
 MAILING ADDRESS Silver Springs NV PO 428? 89429

2. LOCATION SW 1/4 NE 1/4 Sec. 30 T. 17 N. R. 25 E Lyon County
 PERMIT NO. 1744409 Parcel No. Riverside Sub # 1 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fine sand		0	2	2
sand + clay mix		2	6	4
sand		6	15	9
brown clay		15	20	5
sand + brown clay		20	49	29
sand	x	49	70	21
brown clay		70	74	4
gray clay		74	79	5
dark gray clay		79	82	3
white + black sand	x	82	90	8
white sand coarse gravel	x	90	98	8
dark brn clay		98	100	2

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 1/2 Inches 0 Feet 50 Feet
6 Inches 50 Feet 100 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	100

Perforations:
 Type perforation factory slot
 Size perforation 3" + 3/32
 From 80 feet to 100 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality good

Date started 8 30, 1993
 Date completed 9 17, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>25</u>	<u>4 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ed Miller Contractor
 Address P.O. 92 Smith, NV 89430 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1806

Signed [Signature] By driller performing actual drilling on site or contractor
 Date 9/22/93