

OFFICE USE ONLY
 Log No. 4254
 Permit No. _____
 Basin 8-102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18593

1. OWNER Guard L.T.D. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3130 Villa Marbella 3850 Hackberry St.
Cir. Reno, NV 89509-6602 Stagecoach, NV 89429
 2. LOCATION NW 1/4 SE 1/4 Sec. 28 T. 18 N/S R. 24 E. Lyon County
 PERMIT NO. _____ Subdivision Name Mountain View
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, gravel + cobblestone		0	120	120
Brown Clay + gravel		120	238	118
Brown Clay + some same		250	280	30
Coarse sand + Brown Clay	X	280	340	60

'93 SEP 17 P 1:04
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 340 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>71</u>	<u>340</u>

Perforations:
 Type perforation Mill
 Size perforation 18x3
 From 300 feet to 340 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 340 feet

9. WATER LEVEL
 Static water level 205 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 9-5, 1993
 Date completed 9-10, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>30</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ACE Drilling + Development Contractor
 Address P.O. Box 668 Contractor
Silver Springs, NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 14299
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-10-93