

OFFICE USE ONLY  
 Log No. 12547  
 Permit No. 8-105  
 Basin 1

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18970

1. OWNER JOHN OTTMAN ADDRESS AT WELL LOCATION 226 MOUNTAIN REACH CT  
 MAILING ADDRESS PO BOX 521 MINDEN NV 89423  
 LOCATION SW 1/4 SW 1/4 Sec. 3 T 12 R 19 E County CLATSOP  
 PERMIT NO. APN 1904218 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Hard granite</u>		<u>0'</u>	<u>10'</u>	<u>10'</u>
<u>Sandstone</u>	<u>NO</u>			
<u>Some fine SAND</u>				
<u>Gravelly D. q. &amp; OCCASSIONAL ROCK</u>	<u>NO</u>	<u>10'</u>	<u>42'</u>	<u>26'</u>
<u>fractured granite</u>	<u>NO</u>	<u>42'</u>	<u>85'</u>	<u>43'</u>
<u>D. q. &amp; some sand &amp; clay lenses</u>	<u>NO</u>	<u>85'</u>	<u>155'</u>	<u>70'</u>
<u>Broken Rock &amp; sand lenses</u>	<u>YES</u>	<u>155'</u>	<u>180'</u>	<u>25'</u>

'93 AUG 30 PB:02 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
9 7/8 Inches From 0 Feet To 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12</u>	<u>3/16"</u>	<u>0</u>	<u>180</u>

Perforations:  
 Type perforation fact. saw slot  
 Size perforation 3/32"  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50'  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ED MILLER Contractor  
 Address Box 92 Contractor SMITH, NV 89444  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533  
 Signed Scott Chitwood  
 By driller performing actual drilling on site or contractor  
 Date 8 16 93

Date started Aug. 13<sup>th</sup>, 1993  
 Date completed Aug. 16<sup>th</sup>, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>NA</u>	<u>3</u>