

OFFICE USE ONLY
 Log No. 47548
 Permit No. 8-105
 Basin 8-105
 NOTICE OF INTENT NO. 18972

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER PEARSON CONT ADDRESS AT WELL LOCATION 232 SIERRA SHADOWS
 MAILING ADDRESS GARDNERVILLE NV 89410
 2. LOCATION SW 1/4 SW 1/4 Sec 3 T 12 N 19 E DOUGLAS County
 PERMIT NO. APN 19 052 04 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY D. G.	NO	0'	24'	24'
Granite Rock	NO	24'	32'	8'
frag. Granite D. G.	NO	32'	65'	33'
HARD Granite Boulders	NO	65'	90'	25'
Cemented d. g. OCCASIONAL Rocks - some clay lenses	NO	90'	138'	48'
frag. Granite rocks & clay lenses	YES	138'	170'	32'
SAND & CLAY layered	YES	170'	200'	30'

AUG 30 P 3:02
STATE ENGINEERS (C)

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12</u>	<u>3/16"</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation FACT. SAW SLOT
 Size perforation 3/32"
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow NA G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started Aug. 6TH 1993
 Date completed Aug. 9TH 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60+</u>	<u>NA</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address PO BOX 92
SMITH NV 89444
 Nevada contractor's license number 32166
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1533
 Division of Water Resources, the on-site driller
 Signed Scott Chittwood
 By driller performing actual drilling on site or contractor
 Date 8/9/93