WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42553
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 25359

1. OWNER George Olson
MAILING ADDRESS 772 Saddlecrest
Gard NV 89410

ADDRESS AT WELL LOCATION 840 Regalia
Gard NV

2. LOCATION SW ¼ SE ¼ Sec. 13 T. 12 N S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 29-441-29 (Parcel No.) Ruhnstroth (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	15	
SAND & GRAVEL		15	35	
CLAYS SANDS & GRAVEL		35	60	
GRAVEL & ROCK		60	75	
ROCK		75	95	
GRAVEL SAND & ROCK		95	115	
CLAY SAND & GRAVEL		115	140	
ROCKS & GRAVEL	XX	140	190	
CLAY-GRAVEL	XX	190	215	
CLAY GRAVEL & ROCK	XX	215	260	

'93 SEP -9 A11:18
RECEIVED
STATE ENGINEERS OFFICE

Date started 8-24, 1993
Date completed 8-30, 1993

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	20-30+	5 ft	3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 262 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.5 lbs	.188"	0'	260'

Perforations:
Type perforation Factory Feet
Size perforation 3"x5/32"
From feet to feet
From 260 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 260 feet to 80 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature – °F Quality –

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchack Drilling Inc. (Contractor)
Address PO Box 1359 (Contractor)
Minden NV 89423
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen (By driller performing actual drilling on site or contractor)
Date 9-8-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627