WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42954
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 20847

1. OWNER Don Griffin
MAILING ADDRESS P.O. Box 1 of Gardnerville, Nev. 89410
ADDRESS AT WELL LOCATION 921 Riverview Gardnerville Nev.

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 12 N/S R. 20 E Douglas County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Soil & cobbles	No	0'	5	5'
		5'	60	55'
Some boulders, Cobbles, & sand	No			
Broken Rock, Clays, & Cemented gravel	No	60'	90	30'
Washed gravel & occassional Rock	Yes	90	135	45'
heavy gravel	Yes	135	190	55'
large gravels Some sand lenses	Yes	190	230	40'
Large gravel & cobbles	Yes	230	275	45'

RECEIVED STATE ENGINEER'S OFFICE SEP -9 '93 AM 11:18

Date started 7-21, 1993
Date completed 7-28, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		2

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)
9 7/8" Inches From 0' Feet To 275 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12	.188	0'	

Perforations:
Type perforation Fact. Saw Slot
Size perforation 3/32
From 215 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50' feet to 275 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchack Drilling inc. (Contractor)
Address Minden Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 15127
Signed Scott Chitwood (By driller performing actual drilling on site or contractor)
Date 7-30-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627