

OFFICE USE ONLY
 Log No. 42555
 Permit No. 8-105
 Basin. I
 NOTICE OF INVENT NO. 24306

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER HEARTH SIDE HOMES ADDRESS AT WELL LOCATION 1977 MULE GARDNERVILLE, NV
 MAILING ADDRESS MINDEN, NV

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 12 N. R. 20 E DOUGLAS County
 PERMIT NO. 29-451-26 Parcel No. RUHENSTROTH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/ GRAVEL		0	78	78
CLAY		78	84	6
SANDY CLAY		84	120	36
SANDY CLAY w/ COBBLES		120	163	43
SANDY CLAY w/ GRAVEL		163	182	19
SAND + GRAVEL	✓	182	189	7
SANDY CLAY w/ GRAVEL		189	201	12
SAND + GRAVEL	✓	201	207	6
SANDY CLAY w/ GRAVEL		207	215	8

'93 AUG 19 AM 11:18
 STATE ENGINEERS

8. WELL CONSTRUCTION
 Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 215 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>215</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 190 feet to 210 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 215 feet

9. WATER LEVEL
 Static water level 15.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 7-19, 1993
 Date completed 7-22, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>10+</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 7-22-93