

OFFICE USE ONLY  
Log No. 42538  
Permit No. \_\_\_\_\_  
Basin 8-105  
NOTICE OF INTENT NO. 20852

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bill Garrison ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS Box 43 232 Limousine C.T.  
Genoa, NV 89411 Genoa, NV  
2. LOCATION SW 1/4 NW 1/4 Sec. 10 T. 13 N. R. 19 E. Douglas County  
PERMIT NO. 17-111-62 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden - Broken Rock, Boulders &amp; Dirt</u>	<u>no</u>	<u>0</u>	<u>42'</u>	<u>42'</u>
<u>Semi Hard Granite Rock &amp; some clay layers</u>	<u>no</u>	<u>42'</u>	<u>68'</u>	<u>26'</u>
<u>Alluvial Broken Rock &amp; some clay layers</u>	<u>yes</u>	<u>68'</u>	<u>135'</u>	<u>67'</u>
<u>Gravel &amp; clay mix</u>	<u>yes</u>	<u>135'</u>	<u>150'</u>	<u>15'</u>
<u>Brn. clay</u>	<u>no</u>	<u>150'</u>	<u>165'</u>	<u>15'</u>

8. WELL CONSTRUCTION  
Depth Drilled 165 Feet Depth Cased 165 Feet  
HOLE DIAMETER (BIT SIZE)  
9 7/8 Inches From 0 Feet To 165 Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 9/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>165</u>

Perforations:  
Type perforation fact saw slot  
Size perforation 3.82  
From 110 feet to 150 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 50  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 50 feet to 165 feet

9. WATER LEVEL  
Static water level 35 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60.0 °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name KANCHAK Drilling, Inc. Contractor  
Address Minden, Nev. Contractor

Nevada contractor's license number issued by the State Contractor's Board 021268  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533  
Signed Scott Chittwood  
By driller performing actual drilling on site or contractor  
Date 6-16-93

Date started 6-10, 1993  
Date completed 6-14, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>55+</u>	<u>NA</u>	<u>5</u>

'93 SEP -9 AM 11  
 RECEIVED  
 STATE ENGINEERS OF NV