

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20915

1. OWNER BENTLEY NEVADA CORP ADDRESS AT WELL LOCATION NONE AT THIS TIME  
 MAILING ADDRESS Box 157  
MINDEN, NV 89423

2. LOCATION SW 1/4 NE 1/4 Sec 32 T 13 N R 21 E DOUGLAS County  
 PERMIT NO. 52018/52019 23-170-21 NONE  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	3	3
FINE SAND W LARGE COBBLES		3	57	54
TAN CLAYEY SAND		57	63	6
MED GRVL W SOME SAND	X	63	94	31
RED BWN CLAYEY SAND		94	101	7
SMALL GRVL W THIN LAYERS OF CLAYEY GRVL	X	101	206	105
LARGER GRVL W MINOR SAND 1/2 LITTLE CLAY	X	206	250	44

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)  
 From 135/8 Inches 0 Feet 250 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>.210</u>	<u>+2</u>	<u>250</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3x 3/32  
 From 120 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 250 feet

9. WATER LEVEL  
 Static water level 59 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 54 °F Quality \_\_\_\_\_

Date started 9/23 1992  
 Date completed 9/25 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>	<u>/</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address Box 21548 Contractor  
CARSON CITY, NV 89721  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed Joseph J. Keisek  
By driller performing actual drilling on site or contractor  
 Date 9/26/92