WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42567
Permit No.
Basin 9-107

NOTICE OF INTENT NO. 24240

1. OWNER MR SKAGGS
MAILING ADDRESS
ADDRESS AT WELL LOCATION 75 WELLINGTON WELLINGTON CUT OFF, WELLINGTON

2. LOCATION NW ¼ SE ¼ Sec. 12 T. 10 (N)S R. 23 E LYON County
PERMIT NO. (Issued by Water Resources) 10-711-07 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BOULDERS W/ SANDY CLAY		0	75	
SANDY CLAY		75	81	
BOULD. W/ SANDY CLAY		81	85	
SANDY CLAY		85	92	
LO. GRVLS W/ SANDY CLAY		92	98	
GRAV. W/ SANDY CLAY		98	176	
BOULD. W/ SANDY CLAY		176	182	
GRAV. W/ SANDY CLAY		182	197	
SANDY CLAY W/ GRAV.		197	238	
COARSE SAND W/ SM GRV.	WB	238	250	
SANDY CLAY		250	260	
BOULD W/ SANDY CLAY		260	280	

Date started 7-26, 1993
Date completed 7-30, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	NA	
	120	8½

8. WELL CONSTRUCTION
Depth Drilled 280' Feet Depth Cased 280' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 7/8"	0	280

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	280

Perforations:
Type perforation FACTORY
Size perforation 3/32" X 3"
From 280 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 280 feet

9. WATER LEVEL
Static water level 120' feet below land surface
Artesian flow G.P.M. 25+ P.S.I.
Water temperature 130° °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER (Contractor)
Address BOX 92 (Contractor)
SMITH, NV 89444
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed 8/93 (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627