

OFFICE USE ONLY
 Log No. 42569
 Permit No. _____
 Basin R-107
 NOTICE OF INTENT NO. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SHELBY R/RODWIN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO BOX 481 77 LOWER COLONY
GARDNERVILLE NV 89410 WELLINGTON NV
 2. LOCATION NE 1/4 SW 1/4 Sec 4 T. 11 N. S. R. 23 E LYON County
 PERMIT NO. APN 10 35117 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>CLAY Sand</u>	<u>no</u>	<u>0</u>	<u>2'</u>	<u>2'</u>
<u>COARSE SAND &</u>				
<u>CLAY mix</u>	<u>no</u>	<u>8'</u>	<u>32'</u>	<u>24'</u>
<u>RM. CLAY</u>	<u>no</u>	<u>32'</u>	<u>55'</u>	<u>23'</u>
<u>Washed gravel</u>	<u>no</u>	<u>55'</u>	<u>70'</u>	<u>15'</u>
<u>Cemented gravel & clay</u>	<u>no</u>	<u>70'</u>	<u>105'</u>	<u>35'</u>
<u>SAND & gravel</u>	<u>no</u>	<u>105'</u>	<u>130'</u>	<u>25'</u>
<u>Broken rock & CLAY</u>	<u>no</u>	<u>130'</u>	<u>150'</u>	<u>22'</u>
<u>Blue clay & some sand lenses</u>	<u>yes</u>	<u>152'</u>	<u>170'</u>	<u>25'</u>
<u>Cemented gravel & s. q. clay and some clay layers</u>	<u>yes</u>	<u>170'</u>	<u>200'</u>	<u>30'</u>

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.57</u>	<u>12</u>	<u>.128</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation Act. S&W Slot
 Size perforation 3/32
 From _____ feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 200 feet

9. WATER LEVEL
 Static water level 60' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Aug. 27th 1993
 Date completed Aug. 29th 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50⁺</u>	<u>N/A</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address PO BOX 92 Contractor
SMITH NV 89444
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
 Signed Scott Chittard
 By driller performing actual drilling on site or contractor
 Date Aug. 29th