WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42576
Permit No.
Basin 10-121A

NOTICE OF INTENT NO. 18157

1. OWNER Wells Cargo
MAILING ADDRESS 1775 E. 4th Reno Nv. 89505
ADDRESS AT WELL LOCATION Washington & First Ave. Luning, Nevada

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 8 (N) S R. 34 E. Mineral County
PERMIT NO. M/0 599 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE Enviro.
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown, dense-v. dense silty sand with interbedded sandy clay clayey sand and occasional gravel stringers | X | 0 | 120 | 120 |
| | | 92 | 120 | 27 |

Date started ..., 19..
Date completed ..., 19..

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10.5 Inches | | 0 Feet | 120 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | 1½#/Ft. | .25 | 0 | 120 |
| | | | | |
| | | | | |

Perforations:
Type perforation .020 slot F480 PVC
Size perforation
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 57
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 57 feet to 120 feet

9. WATER LEVEL
Static water level 92.0 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 58 °F Quality Being Monitored

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name West Hazmat Drilling Corp. (Contractor)
Address 3233 Fitzgerald Rd. (Contractor)
Rancho Cordova, Ca. 95742
Nevada contractor's license number issued by the State Contractor's Board C23-31386
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1882
Signed Bob Gaushey (By driller performing actual drilling on site or contractor)
Date 6-28-1993

'93 JUL 12 P2:03
STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627