

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18064

1. OWNER Nevada First Corporation ADDRESS AT WELL LOCATION Davey Town
 MAILING ADDRESS P.O. Box 490
Winnemucca NV 89445
 2. LOCATION nw 1/4 nw 1/4 Sec. 29 T. 38 n. N/S R. 37 E Humboldt County
 PERMIT NO. 34813
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	4	4
hardpan		4	5	1
sand Coarse		5	8	3
granite sand & small rock 3"-		8	110	102
brn sandy clay		110	113	3
fine brn sand & sandstone	x	113	125	12
fine to crse sand	x	125	128	3
sandstone & gravel	x	128	137	9
med sand & gravel	x	137	140	3
sandstone & Gravel	x	140	145	5
sand & flat shale	x	145	161	16
sandstone & clay	x	161	168	7
sand & gravel	x	168	171	3
sandstone & Clay		171	179	8
sand & gravel	x	179	182	3
sandstone & clay		182	202	20
fine to crse sand	x	202	208	6
sandstone & Clay		208	211	3
fine to crse sand	x	211	220	9
clay & sandstone		220	225	5
fine to crse sand	x	225	229	4
brn clay		229	320	91
green shale		320	325	5
blue clay		325	331	6
brn clay		331	332	1
sand & pea gravel		332	335	3
brn sandy clay		335	432	97

8. WELL CONSTRUCTION
 Depth Drilled 535 Feet Depth Cased 535 Feet
 HOLE DIAMETER (BIT SIZE)
 From 28 Inches 0 Feet 535 Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	42.05	.250	+2	142
"	"	"	180	200
"	"	"	230	330

Perforations:
 Type perforation Continous Wire
 Size perforation .40
 From 140 feet to 180 feet
 From 200 feet to 230 feet
 From 330 feet to 340 feet
 From 425 feet to 435 feet
 From 455 feet to 475 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 535 feet to 50 feet

Date started July 28 1993
 Date completed August 4 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
865	195	.25	
840	170	1	
810	130	.4	

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature 58 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pete Cope Drilling Co., Inc. Contractor
 Address 6505 W Chinden Contractor
Meridian ID 83642
 Nevada contractor's license number issued by the State Contractor's Board 13443
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1456
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 8/28/93

