

OFFICE ONLY
 Log No. 42596
 Permit No. _____
 Basin 41-44

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10033

1. OWNER DUSTY LYNN DRY ADDRESS AT WELL LOCATION North side
 MAILING ADDRESS Elko NV 89803 US 7th Street and corner of 7th Ave
Ryndon
 2. LOCATION 36 1/4 212 1/4 Sec 36 T 36 N R 56 E Elko County
 PERMIT NO. 016078061001 Humboldt River Ranches Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>SANDSTONE</u>		<u>3</u>	<u>27</u>	<u>24</u>
<u>Low gravel</u>		<u>27</u>	<u>38</u>	<u>11</u>
<u>CLAY</u>		<u>38</u>	<u>60</u>	<u>22</u>
<u>SAND, CLAY</u>		<u>60</u>	<u>80</u>	<u>20</u>
<u>SAND</u>		<u>80</u>	<u>97</u>	<u>17</u>
<u>CLAY</u>		<u>97</u>	<u>126</u>	<u>29</u>
<u>gravel</u>		<u>126</u>	<u>139</u>	<u>13</u>
<u>CLAY</u>		<u>139</u>	<u>142</u>	<u>3</u>
<u>SAND</u>		<u>142</u>	<u>146</u>	<u>4</u>
<u>CLAY</u>		<u>146</u>	<u>153</u>	<u>7</u>
<u>Hard & Chert</u>	<u>X</u>	<u>153</u>	<u>159</u>	<u>6</u>
<u>SAND, CLAY</u>		<u>159</u>	<u>161</u>	<u>2</u>
<u>CLAY</u>		<u>161</u>	<u>176</u>	<u>15</u>
			<u>TD</u>	

8. WELL CONSTRUCTION
 Depth Drilled 176 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 170 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>176</u>

Perforations:
 Type perforation SLOTS
 Size perforation 3/16" x 3/16"
 From 155 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 176 feet

9. WATER LEVEL
 Static water level 130' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 61.5 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fighting Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 31964
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shelton T. ...
 By driller performing actual drilling on site or contractor
 Date 9-12-93

Date started 8-13, 1993
 Date completed 8-15, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>23</u>		<u>2.5</u>

'93 SEP 20 P 2:17
 RECEIVED
 STATE ENGINEERS OFFICE