WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

BCB

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42597
Permit No.
Basin 4-44

NOTICE OF INTENT NO. 19198

1. OWNER Dew INC
MAILING ADDRESS PO Box 3111
Elko NV 89803

ADDRESS AT WELL LOCATION Lot A CORNER of Eight ST and Taft AVE

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 36 N/S R. 56 E Elko County
PERMIT NO. Issued by Water Resources | A NW¼ SW¼ NW¼ Parcel No. | Rynda Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	5	5
SANDSTONE		5	30	25
SANDY CLAY		30	50	20
CLAY		50	70	20
SANDSTONE		70	85	15
SANDY gravel		85	100	15
SANDSTONE		100	125	25
CLAY		125	128	3
gravel		128	134	6
CLAY		134	146	12
gravel	x	146	153	7
SAND		153	160	7
SANDY CLAY		160	167	7
CLAY		167	170	3

Date started 7-20, 1993
Date completed 8-1, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
28		4.6

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	170 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	170

Perforations:
Type perforation Slots
Size perforation 3/16 x 3"
From 145 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 170 feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling co (Contractor)
Address PO Box 525 (Contractor)
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-11-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627