

OFFICE USE ONLY  
 Log No. 42598  
 Permit No. 4-44  
 Basin 1-44

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10932

1. OWNER DEW INC ADDRESS AT WELL LOCATION South of Seventh  
 MAILING ADDRESS PO Box 3111 STREET AND TART AVE  
ELKO NV 89803 PATTON  
 2. LOCATION NW 1/4 SW 1/4 Sec 36 T 36 N/S R 56 E ELKO County  
 PERMIT NO. 06-33H-404 Rynder Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	4	4
SANDSTONE		4	20	16
GRAVEL SAND		20	25	5
CLAY		25	30	5
SANDY CLAY		30	65	35
SANDSTONE		65	80	15
GRAVEL & SAND		80	87	7
CLAY		87	108	21
SANDY CLAY		108	127	26
GRAVEL SAND	X	127	150	23

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	1.88	+2	150

Perforations:  
 Type perforation slots  
 Size perforation 3/16 x 3"  
 From 150 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 57  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 57 feet to 150 feet

9. WATER LEVEL  
 Static water level 98 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

Date started 8-1, 1993  
 Date completed 8-3, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>3</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address PO Box 525 Contractor  
ELKO NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shouk J. J...  
 By driller performing actual drilling on site or contractor  
 Date 8-10-93