WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA #1
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4261B
Permit No.
Basin 4-48

NOTICE OF INTENT NO. 23937

1. OWNER TEHAMA HOLDINGS
MAILING ADDRESS 100 West Grove Suite 125
Reno, NV 89509

ADDRESS AT WELL LOCATION North side of Pickering between 15th and 16th street

2. LOCATION NE ¼ SW ¼ Sec. 17 T 32 N/S R 55 E Elko County
PERMIT NO. Issued by Water Resources | 28-015-06 Parcel No. | Lucky Nugget #2 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Gravel		2	4	2
Quartz		4	80	76
Silicified rock		80	200	120
Red volcanic		200	300	100
Silicified rock		300	480	180

93 JUN 21 P2:30 STATE ENGINEER'S OFFICE

Date started June 8, 19 93
Date completed Juue 11, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	20		6

8. WELL CONSTRUCTION
Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	480 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1 1/2	480

Perforations:
Type perforation Mill slot
Size perforation 3 x 1/8
From 440 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal ~~30~~ 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 480 feet

9. WATER LEVEL
Static water level 375 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. Contractor
Address P.O. Box 850 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dan Weash
By driller performing actual drilling on site or contractor
Date 6-18-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627