WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA #3
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42616
Permit No.
Basin 41-48

NOTICE OF INTENT NO. 23942

1. OWNER TEHAMA HOLDINGS
MAILING ADDRESS 100 West Grove Suite 125
Reno, NV 89509

ADDRESS AT WELL LOCATION South side of Pickering between 16th and 17th street

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 32 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 28-017-02 (Parcel No.) Lucky Nugget #2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Siltstone		2	40	38
Silicified rock		40	200	160
Red volcanic		200	340	140
Silicified rock		340	440	100

'93 JUN 21 P2:31
STATE ENGINEERS OFFICE

Date started June 12, 19 93
Date completed June 16, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	50		6

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	440 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	440

Perforations:
Type perforation Mill slot
Size perforation 3 x 3/16
From 420 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From ~~30~~ 50 feet to 440 feet

9. WATER LEVEL
Static water level 375 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dave Hess (By driller performing actual drilling on site or contractor)
Date 6-18-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627