



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10029

1. OWNER JOM C NORRIS ADDRESS AT WELL LOCATION 9th and Cleveland
 MAILING ADDRESS Elko NV 89803
 2. LOCATION S.E. 1/4 SW 1/4 Sec. 25 T 36 N R 35 E ELKO County
 PERMIT NO. 12-038-25-5 Parcel No. 56E Ryndon Subdivision Name Humboldt River Ranches
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	2	2
Gravel		2	15	13
SANDSTONE		15	33	18
CLAY		33	58	25
SANDSTONE		58	105	47
CLAY		105	118	13
SANDY CLAY		118	150	32
Gravel		150	157	7
SANDSTONE		157	163	6
Gravel		163	168	5
CLAY		168	175	7
SANDSTONE		175	198	13
CLAY		198	240	42
SAND Gravel	K	240	260	20

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 260 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>72</u>	<u>260</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3
 From 235 feet to 260 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 57
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 57 feet to 260 feet

9. WATER LEVEL
 Static water level 170 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fentig Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 31964
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shaul C Fentig
 By driller performing actual drilling on site or contractor
 Date 9-13-93

Date started 8-18, 1993
 Date completed 8-20, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>28</u>		<u>2.5</u>

'93 SEP 20 P2:17
 RECEIVED
 STATE ENGINEERS OFFICE