

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 42639  
 Permit No. 049  
 Basin 4

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13030

1. OWNER DEW INC Retirement Bldg ADDRESS AT WELL LOCATION Retirement Bldg on 12th St. NE corner of 8th St. & 12th St. Reno NV  
 MAILING ADDRESS 1500 Bess Hill Reno NV 89503 Clark County  
 2. LOCATION SE 1/4 Sec 25 T 36 N 36 R 50 E Elk  
 PERMIT NO. 12-038-06-3 Issued by Water Resources Parcel No. 12-038-06-3 Subdivision Name Humbolt River Ranch

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	2	2
SANDSTONE		2	17	15
Gravel		17	28	11
CLAY		28	76	48
SANDY CLAY		76	105	29
Gravel		105	112	7
CLAY		112	150	38
Gravel		150	156	6
SAND & Gravel		156	164	8
CLAY		164	243	79
SAND & Gravel		243	260	17

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 120 Feet  
 6 Inches 170 Feet 260 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	1.88	72	170
4.2	8.66	1.88	160	260

Perforations:  
 Type perforation S.I.C.F.  
 Size perforation 3/8" & 1/2"  
 From 120 feet to 120 feet  
 From 240 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 56  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 56 feet to 170 feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.5 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fortis Drilling Co Contractor  
 Address 120 Bess Hill Reno NV 89503 Contractor  
 Nevada contractor's license number 31904 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shane C. Feltus By driller performing actual drilling on site or contractor  
 Date 9-13-93

Date started 8-15 1993  
 Date completed 8-18 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>3</u>

1993 SEP 20 P2:17  
 RECEIVED  
 STATE ENGINEERS OFFICE