PZ93-10

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42657, 43441
Permit No.
Basin 4-61

NOTICE OF INTENT NO. 20177

1. OWNER Barrick Goldstrike
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 36 N/~~S~~ R. 50 E. EUREKA County

PERMIT NO. WAIVER#M/O-441 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRANITE DYRITE		0	525	525
CLAY		525	530	5
GRANITE DYRITE		530	820	290

42657
43441

'93 SEP 21 P2:06
STATE ENGINEER'S OFFICE

Date started SEPTEMBER 6, 1993
Date completed SEPTEMBER 9, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 820 Feet Depth Cased 797 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	21 Feet
6-1/2 Inches		21 Feet	820 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	33	.375	0	21
#1: 1¼	2	SCH 40	0	597
#2: 1¼	2	SCH 40	0	397

Perforations:
Type perforation SLOT
Size perforation .025
From #1: 597 feet to 797 feet
From #2: 397 feet to 497 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From #1: 586-820 feet to #2: 386-512 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed John Lengitz
By driller performing actual drilling on site or contractor

Date SEPTEMBER 15, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627