PZ93-8

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42658, 42659
Permit No.
Basin 4-61

NOTICE OF INTENT NO. 20172

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ NW ¼ Sec 30 T 36 N/X R 50 E EUREKA County

PERMIT NO. WAIVER#M/O-441 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRANITE DYRITE		0	685	685

log # 42658 42659

'93 SEP 21 P2:06 STATE ENGINEERS OFFICE

Date started AUGUST 27, 19 93
Date completed AUGUST 30, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 685 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	20 Feet
6-3/4 Inches		20 Feet	685 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	33	.375	0	20
#1: 1¼		SCH 40	0	180
#2: 1¼		SCH 40	0	420

Perforations:
Type perforation SLOT
Size perforation .025
From #1 180 feet to 280 feet
From #2 420 feet to 620 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From #1: 174-284 feet to #2: 410-685 feet

9. WATER LEVEL
Static water level NONE feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the ~~on-site~~ driller 1773

Signed [signature] (By driller performing actual drilling on site or contractor)

Date AUGUST 30, 1993

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627