WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42095
Permit No.
Basin 4-69

NOTICE OF INTENT NO. 24061

1. OWNER Victor & Paulin Lambert
MAILING ADDRESS 3700 W. Lambert Drive
Winnemucca, Nevada 89445

ADDRESS AT WELL LOCATION 3535 Lambert Drive

2. LOCATION S.W. ¼ N.E. ¼ Sec. 21 T. 37 N. N/S R. 38 E. E Humboldt County
PERMIT NO. A.P.N. 06-514-10 (Issued by Water Resources) | Block C. Lot #10 (Parcel No.) | 5 Mile Acres (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil brown.		0	2	2
Clay brown.		2	5	3
Gravely clay brown.		5	42	37
Gravel brown.		42	61	19
Sand & gravel brown.	39	61	100	39

'93 JUN 15 A11:09

Date started June 16, 1993
Date completed June 17, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	40'	3

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	100

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	.188	0	100

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 65' feet to 100' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50'
Placement Method: [x] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. & R. Drilling (Contractor)
Address P.O. Box 1982 (Contractor)
Winnemucca, Nevada 89446
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas (By driller performing actual drilling on site or contractor)
Date June 29, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627