WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43415
Permit No.
Basin 4-70

NOTICE OF INTENT NO. 24062

1. OWNER Mike Jones
MAILING ADDRESS 7410 Rose Creek Road
Winnemucca, Nevada 89445

ADDRESS AT WELL LOCATION 7410 Rose Creek Rd.

2. LOCATION S.W. ¼ N.E. ¼ Sec. 17 T. 35 N. N/S R. 37 E. Humboldt County
PERMIT NO. A.P.N. 13-233-18 (Issued by Water Resources) Lot # 67 (Parcel No.) Sonoma Rancho's # 2 (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[x] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil brown.		0	2	2
Clay brown, hard.		2	9	7
Sandy clay, brown.		9	61	52
Gravely clay, brown.		61	83	22
Sand & gravel, brown.	17	83	100	17

'93 JUL 29 P2:22
STATE ENGINEER

Date started June 19, 1993.
Date completed June 26, 1993.

7. WELL TEST DATA
TEST METHOD: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5'	3

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0' Feet	50' Feet
6" Inches	50' Feet	100' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	14	.188	0'	100'

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 75' feet to 100' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 54' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. & R. Drilling (Contractor)
Address P.O. Box 1982 (Contractor)
Winnemucca, Nevada 89446
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas [illegible] (By driller performing actual drilling on site or contractor)
Date June 24, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627