

Log # 42733

HUMBOLDT DRILLING & PUMP CO., INC.

P.O. BOX 590
4675 W. WINNEMUCCA BLVD.
WINNEMUCCA, NEVADA 89446
(702) 623-5259

August 25, 1993

Division of Water Resources
123 W. Nye Lane
Carson City, NV 89710

Re: Abandonment of Well
Old Fish Hatchery
Neil Road

Gentlemen:

We tried to clean this well, pulled out rocks and could go no further than 50'.

The State asked that we go in with a rotary rig and grind up from 50' to 80' of rocks that were possibly in this hole. When we got there we found no rocks in this hole. We attempted to drill down with a 12" bit. Making no progress, we put a 8" bit on and continued to lock up. We pulled the bit up to check it and found metal particals on the bit as well as several broken teeth.

Assuming a pump is in this well, I called Division of Water Resources and talked to Tom Gallagher.

I proceeded to put 2" pipe down the well. We got it to go to 100' which is 50' past the top of the pump. I ordered six yards of neat cement from American Ready Mix and had O'Riley, with his grout pump, pump this neat cement down the well. Of the six yards, there was approximately one wheel barrow of neat cement left over in the truck.

I left the diverter and plug sticking up out of the ground 2'. Rosaschi Construction is going to dig around the casing and cut off below ground level as there was thin slurry at the upper level.

Sincerely,

Gary D. Tompkins
(MA)

Gary D. Tompkins
License #1154

GDT/ma