WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42740
Permit No.
Basin 6-59

NOTICE OF INTENT NO. 25452

1. OWNER Susie Askew
MAILING ADDRESS 2995 White Pine New Washo City
ADDRESS AT WELL LOCATION 2995 White Pine New Washo City

2. LOCATION ~~NE~~ ¼ ~~NW~~ ¼ Sec ~~[illegible]~~ T 17 N S R 20 E Washo County
PERMIT NO. SW SE (31) 50-405-12 New Washo City #4
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☑ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Sand & Gravels		2	25	23
Course Sands		25	52	27
Brown Clays With Inbeded Gravels		52	63	11
Gray Silty Clays		63	98	35
Green & White D.G. Sands	XXX	98	118	20
HARD, DG. Sands & Gravels		118	125	7

'93 OCT -4 A11:23
RECEIVED
STATE ENGINEERS OFFICE

Date started 9-17, 1993
Date completed 9-18, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	30	3

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)
10 3/4 Inches From 0 Feet To 125' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	125'

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 125' feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address 5551 Hwy. 50 East #5 Carson City, Nevada 89 Contractor
[illegible]-0459 - [illegible]
[illegible]

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quinton R. Butts
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627