WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42751
Permit No.
Basin 7-926

NOTICE OF INTENT NO. 21841

1. OWNER LENNY MUNSHAW
MAILING ADDRESS 535 Big KNob Drive
Sun Valley, NV 89433

ADDRESS AT WELL LOCATION
11370 Deodar
Reno, NV 89506

2. LOCATION NW ¼ SE ¼ Sec. 23 T. 21N N/S R19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 080-279-07 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	3	2
Coarse granite sands		3	6	3
Brown sandy clay		6	18	12
Brown clay		18	59	41
Soft zone (NO WATER)		59	63	4
Brown sandy clay		63	94	31
Coarse sands	X	94	97	3
Brown clay with sand streaks		97	129	32
Coarse sands with clay streaks	X	129	160	31
Brown clay		160	162	2

'93 SEP 30 A10:47 STATE ENGINEER'S OFFICE

Date started 9-22-93, 19
Date completed 9-23-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	162	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	162

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 137 feet to 157 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 162 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, INc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 23, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627