

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23784

1. OWNER Scott & Judy Brown ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 5454 1472 Antelope Valley Rd
Reno, Nv 89513

2. LOCATION NW 1/4 NE 1/4 Sec 23 T 22 N/S R 19 F Washoe County
 PERMIT NO. 079-470-0789 - Red Rock Estates #102 Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN YELLOW WHITE fine D.G. sand		0	2	2
Brown clay		2	5	3
Green brown yellow white D.G. with tan clay		5	128	123
Green yellow brown white D. G. sands & gravels		128	217	89
Green brown red white volcanic rock semi fractured		217	221	4
Coarse sands & gravels green orange brown white		221	258	37
T.D. 258 ft				

8. WELL CONSTRUCTION
 Depth Drilled 258 Feet Depth Cased 258 Feet

HOLE DIAMETER (BIT SIZE)
 10 5/8 Inches From 0 Feet To 57 Feet
 8 1/2 Inches 57 Feet 258 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	258

Perforations:
 Type perforation Johnson screen
 Size perforation .030
 From 235 feet to 245 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 54 feet to 258 feet

Date started 8/18/93 19_____
 Date completed 8/19/93 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		3 1/2

9. WATER LEVEL
 Static water level 123 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed _____
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 8/20/93