

OFFICE USE ONLY  
 Log No. 42754  
 Permit No. \_\_\_\_\_  
 Basin 7-94

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13014

1. OWNER Lewis Cary ADDRESS AT WELL LOCATION 1290 Deer Lodge Rd  
 MAILING ADDRESS 2075 McCloud Lot 106  
Reno, Nv 89512  
 2. LOCATION NE NEW 1/4 Sec 8 T 22 N/S R 19 E. Washoe County  
 PERMIT NO. 79-382-07-21 - Red Rock Estates #106 part 2  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown & tan clay with broken volcanic rock		0	7	7
Green clay with green sands D.G.		7	665	58
Green yellow white D.G. sand with small green clay zones		665	688	23
Green clay with small sand zones		688	746	58
Coarse sand zones with green clay stringers		746	770	30
Green gumbo clay		778	822	44
Green white yellow sands with semi fractured rock same		822	879	57
T.D. 879 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 880 Feet Depth Cased 879 Feet  
 HOLE DIAMETER (BIT SIZE)  

Inches	From	To	Feet	Feet
<u>10 1/2</u>	<u>0</u>	<u>57</u>	<u>57</u>	<u>57</u>
<u>8 1/2</u>	<u>57</u>	<u>880</u>	<u>880</u>	<u>880</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>879</u>

Perforations:  
 Type perforation factory  
 Size perforation 3/32 / X 3  
 From 799 feet to 819 feet  
 From 839 feet to 859 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54  
 Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 470 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Islands Dr Suite L  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number 1511  
 issued by the Division of Water Resources, the on-site driller.  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 7/14/93

Date started 7/2/93, 19\_\_\_\_\_  
 Date completed 7/14/93, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>3/4</u>	<u>870</u>	<u>2</u>