WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42758
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 23430

1. OWNER James & Martha Johnson
MAILING ADDRESS P.O. Box 2572, Fallon, NV 89407
ADDRESS AT WELL LOCATION 4141 Willow Creek DR., Fallon, NV 89406

2. LOCATION SE ¼ SW ¼ Sec. 9 T 18 N/S X R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) 6-471-35 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Sand | | 0 | 18 | 18 |
| Brown Clay | | 18 | 26 | 8 |
| Fine Gray Sand | | 26 | 55 | 29 |
| Brown Clay | | 55 | 57 | 2 |
| Coarse & Fine Brown Sand | X | 57 | 65 | 8 |

'93 OCT -7 A10:47
STATE ENGINEER'S OFFICE

Date started Sept 27, 19 93
Date completed Sept 28, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 | 0 | 65 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 60 |
| | | | | |
| | | | | |

Perforations:
Type perforation Well Screen Steel
Size perforation .035
From 60 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 65 feet

9. WATER LEVEL
Static water level 7'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address PO Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 9-29-~~30~~ 93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627