

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 42765  
 Permit No. 8-102  
 Basin 8-102

1. OWNER Bruce Nicholas ADDRESS AT WELL LOCATION 4400 East 3rd Street  
 MAILING ADDRESS 4400 East Third St, Silver Springs NV 89429  
 2. LOCATION SE 1/4 NW 1/4 Sec 10 T 17 N/S R 25 E Lyon County  
 PERMIT NO. NA 17-019-707 Parcel No. Lakeview Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose Sand		0	14	14'
Sand Gravel		14	33	19'
Clay Sand		33	70	37'
Sand Gravel	85	70	85	16'
Clay Gravel	139	85	139	54'

8. WELL CONSTRUCTION  
 Depth Drilled 139 Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 1 Feet 139 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>140</u>

Perforations:  
 Type perforation Mill Perf  
 Size perforation 1/8 x 6 round  
 From 118 feet to 139 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50' feet to 139' feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling Contractor  
 Address PO 599 S.S., NV 89429 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed Leach By driller performing actual drilling on site or contractor  
 Date 8/25/93

Date started 8/17/93 19\_\_\_\_  
 Date completed 8/23/93 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>12-15</u>		<u>5 hrs</u>