WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42769
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 20422

1. OWNER Wayne Tetrault
MAILING ADDRESS 469 San Clemens
Dayton, NV

ADDRESS AT WELL LOCATION 469 San Clemens, Dayton, NV

2. LOCATION NE ¼ SW ¼ Sec. 30 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 03-263-15 (Parcel No.) Mark Twain (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil & Clay (Brown)		0	20	20
gravels		20	60	40
Boulders & gravel		60	80	20
Boulders		80	120	40
Black Schale	✓	120.	240	120

'93 SEP 29 A11:09
RECEIVED
STATE ENGINEERS OFFICE

Date started 9-23, 19 93
Date completed 9-23, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 3 hrs produced about 40 gallons per minute		

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	200 Feet
5 7/8 Inches	200 Feet	240 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	3/16	+1	200
5'	12.	3/16	200	240

Perforations:
Type perforation Air / Torch
Size perforation 1/4 X 1 X 20' X 5 Rows Air 1/4 X 8 X 20' 5 Rows Torch
From 80 feet to 200 feet
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 - 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 165 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature n/a °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tech Drilling Inc (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-25-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627