

OFFICE USE ONLY
Log No. 42771
Permit No. 2-103
Basin 2-103
NOTICE OF INTENT NO. 20421

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Gene Snelone ADDRESS AT WELL LOCATION 6395 Shetland Stage Coach Rd. 89429
MAILING ADDRESS 6395 Shetland Stage Coach Rd. 89429
2. LOCATION NE 1/4 NW 11 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. N/A Issued by Water Resources Parcel No. 19-383-33 Subdivision Name Ranch #2

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil & Sand		0	35	
Boulders & Gravel		35	55	
fine gravel		55	65	
sand & coarse gravel		65	80	
fine/coarse gravel		80	100	
TAN Clay		100	120	
fine Sand		120	130	
coarse gravels				

8. WELL CONSTRUCTION
Depth Drilled.....Feet Depth Cased.....Feet
HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 130 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>71</u>	<u>130</u>

Perforations:
Type perforation a.r. Perf
Size perforation 1/4 x 1 x 20 x 5 ROWS
From 80 feet to 130 feet
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet
Surface Seal: Yes No Seal Type: Heat Cement
Depth of Seal 0-50 Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow.....G.P.M.P.S.I.
Water temperature cold °F Quality good

Date started 8-28, 1993
Date completed 8-29, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Developed for 3 1/2 hrs</u>	<u>Produced about 8 gallons</u>	<u>a minute</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address PO Box 599 Silver Springs NV 89429 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1877
Signed Walter Leach
by driller performing actual drilling on site or contractor
Date 9-25-93