WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42775
Permit No.
Basin
NOTICE OF INTENT NO. 20846

1. OWNER: David Davis
MAILING ADDRESS: 301 E Ocean Blvd, Long Beach, Calif 90802
ADDRESS AT WELL LOCATION: Allerman - Old Foothill Rd, Minden Nv

2. LOCATION: SW ¼ DE ¼ Sec. 3 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. 56296 (Issued by Water Resources) 19-060-34 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil & DG Sand		0	15	
Sand (DG)		15	115	
Sand & Fine Gravel	X	115	145	
Sand & Silts	X	145	200	
Sand		200	240	
Sand & Fine Gravel		240	290	
Sand	X	290	320	
Sandstone & Small Rock	X	320	380	
Sandstone	X	380	400	

'93 OCT 13 P2:27 STATE ENGINEER'S OFFICE

Date started: 7-21, 1993
Date completed: 7-30, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Submersible	420	22'	6 Hr.

8. WELL CONSTRUCTION
Depth Drilled: 400 Feet Depth Cased: 400 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From (Feet)	To (Feet)
	14"	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	13.25 lbs	.188	0	400

Perforations:
Type perforation: Factory Perf
Size perforation: 3 x 5/32"
From feet to feet
From 400 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal: 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 400 feet to 100 feet

9. WATER LEVEL
Static water level: Ø feet below land surface
Artesian flow: 125+ G.P.M. — P.S.I.
Water temperature: — °F Quality: —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Kauchack Drilling Inc.
Address (Contractor): PO Box 1359 Minden Nv 89423
Nevada contractor's license number issued by the State Contractor's Board: #021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: #1495
Signed: Michael Allen (By driller performing actual drilling on site or contractor)
Date: 7-30-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627