

OFFICE USE ONLY
 Log No. 42370
 Permit No. _____
 Basin. 8-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25220

1. OWNER Can. Trelle Const ADDRESS AT WELL LOCATION 1891 Colt Ln
Minden, Nev Gardnerville, Nev
 MAILING ADDRESS P.O. Box 1023
 2. LOCATION N E 1/4 SW 1/4 Sec 1 T 12 N/S R 20 E Douglas County
 PERMIT NO. 29-450-37 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown clay w/ sand</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>cobbles in clay</u>		<u>25</u>	<u>70</u>	<u>45</u>
<u>Sticky Brown clay</u>		<u>70</u>	<u>95</u>	<u>25</u>
<u>saturated gravel + sand</u>	<u>*</u>	<u>95</u>	<u>120</u>	<u>25</u>
<u>sticky clay</u>		<u>120</u>	<u>125</u>	<u>5</u>
<u>saturated gravel</u>	<u>*</u>	<u>125</u>	<u>140</u>	<u>15</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:
 Type perforation Factory milled
 Size perforation 3/32
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 57 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 57 feet to 140 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clear

Date started Sept 28, 1993
 Date completed Sept 28, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enloe Drilling Contractor
 Address P.O. Box 1345 Contractor
Dayton, Nev
 Nevada contractor's license number issued by the State Contractor's Board 4739 A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
 Signed Lee A. Enloe
 By driller performing actual drilling on site or contractor
 Date Sept 29, 1993