

OFFICE USE ONLY  
 Log No. 41778  
 Permit No. 1  
 Basin B-105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24319

1. OWNER WESTWINDS CONST ADDRESS AT WELL LOCATION 771 RUBIO  
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec 20 T. 12 N. R. 20 E DOUGLAS County  
 PERMIT NO. 27-706-03 CHAMBERS FIELD  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sandy brn. clay w/ cobbles		0	7	7
Sand w/ cobbles		7	13	6
Cobbles w/ sand		13	31	18
Sandy brn. clay w/ gravel		31	36	5
Cobbles w/ sandy clay		36	47	11
Sandy brn. clay		47	50	3
Cobbles w/ sand		50	63	13
Cobbles w/ sandy clay		63	67	4
Cobbles w/ sand		67	83	16
gravel w/ sandy clay		83	97	14
gravel w/ sand		97	118	21
Cobbles w/ sand		118	121	3
gravel w/ sand	<u>NVA</u>	121	140	19

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory slotted  
 Size perforation 3 x 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level 45 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.6 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Phinnell  
 By driller performing actual drilling on site or contractor  
 Date 9-13-93

Date started 9-9, 1993  
 Date completed 9-13, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>50+</u>	<u>—</u>	<u>1</u>