

OFFICE USE ONLY  
 Log No. 42779  
 Permit No. \_\_\_\_\_  
 Basin 8-105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24325

1. OWNER ROEDIGER CONSTRUCTION ADDRESS AT WELL LOCATION 696 MARRON  
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION NE 1/4 SW 1/4 Sec 20 T. 12 N S R. 20 E DOUGLAS County  
 PERMIT NO. 27-730-04 CHAMBERS FIELD  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

| Material                                 | Water Strata | From       | To         | Thick-ness |
|------------------------------------------|--------------|------------|------------|------------|
| <u>Sandy brn. Clay &amp; Cobbles</u>     |              | <u>0</u>   | <u>19</u>  | <u>19</u>  |
| <u>Cobbles &amp; sand</u>                |              | <u>19</u>  | <u>41</u>  | <u>19</u>  |
| <u>Sandy brn. clay &amp; cobbles</u>     |              | <u>41</u>  | <u>46</u>  | <u>5</u>   |
| <u>Cobbles &amp; sand</u>                |              | <u>46</u>  | <u>77</u>  | <u>31</u>  |
| <u>Sandy brn. clay &amp; cobbles</u>     |              | <u>77</u>  | <u>80</u>  | <u>3</u>   |
| <u>gravel</u>                            |              | <u>77</u>  | <u>96</u>  | <u>9</u>   |
| <u>Sandy brn. clay &amp; gravel</u>      |              | <u>96</u>  | <u>101</u> | <u>5</u>   |
| <u>gravel w/ short clay streaks, XXX</u> |              | <u>101</u> | <u>140</u> | <u>39</u>  |

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>12</u>           | <u>.188</u>             | <u>0</u>    | <u>140</u> |

Perforations:  
 Type perforation Factory slotted  
 Size perforation 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level 28 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Rhumel  
 By driller performing actual drilling on site or contractor  
 Date 9-24-93

Date started 9-21, 1993  
 Date completed 9-24, 1993

7. WELL TEST DATA

| TEST METHOD:                                                                                    | G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|-------------------------------------------------------------------------------------------------|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |            |                               |              |
| <u>Air</u>                                                                                      | <u>35+</u> | <u>—</u>                      | <u>1</u>     |

'93 SEP 28 AM 10:06  
 RECEIVED  
 STATE ENGINEERS' OFFICE