

OFFICE USE ONLY  
 Log No. 42781  
 Permit No. \_\_\_\_\_  
 Basin 8-105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25260

1. OWNER Genoa Lakes Venture ADDRESS AT WELL LOCATION 2439 Jacks Valley Road  
 MAILING ADDRESS 1597 Esmeralda Genoa, Nevada  
Minden, Nevada 89423

2. LOCATION NE 1/4 SW 1/4 Sec. 3 T. 13 N/S R. 19 E Douglas County  
 PERMIT NO. 57327 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay and Boulders		0	55	55
Broken Black Rock		55	84	29
Broken Black Rock with Traces of Clay		84	87	3
Consolidated Black Rock		87	99	12
Black/White Rust stained Broken Rock		99	127	28
Consolidated Black and White Rock		127	129	2
Broken Gravely Rock		129	150	21
Hard Sandy Clay		150	155	5
Broken Gravely Rock		155	195	40

8. WELL CONSTRUCTION  
 Depth Drilled 195 Feet Depth Cascd 195 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
28	0	50	Feet	Feet
20	50	195	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	.250	+1	195

Perforations:  
 Type perforation Johnson Wire Screen  
 Size perforation .080  
 From 140 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 195 feet

9. WATER LEVEL  
 Static water level 72.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 65 °F Quality Good

Date started August 25, 1993  
 Date completed September 9, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	55.7	24

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sargent Irrigation Company Contractor  
 Address 9955 North Virginia Street Contractor  
Reno, Nevada 89506  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date September 24, 1993