

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 42782  
Permit No. \_\_\_\_\_  
Basin 8-105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24321

1. OWNER MR. POTTER ADDRESS AT WELL LOCATION 2543 FREMONT  
MAILING ADDRESS MINDEN, NV MINDEN

2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 13 N. R. 20 E. DOUGLAS County  
PERMIT NO. 23-510-04 JOHNSON LANE Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravels @ Sandy clay		160	190	30
brown clay		190	205	15
gravels @ Silt clay streaks, etc		205	257	52
Sandy brn. clay		257	263	6
gravels		263	266	3
Sandy brn. clay		266	274	8
gravel @ Sandy clay		274	278	4
Sandy brn. clay		278	289	11
gravel w/ some Sandy clay	XX	289	305	16
Sandy clay		305	309	4
gravel		309	311	2
Sandy clay		311	314	3
Sandy clay w/ gravel		314	318	4
gravel	XXX	318	332	14
Sandy brn. clay		332	333	1

8. WELL CONSTRUCTION  
Depth Drilled 173 Feet Depth Cased 173 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
5 7/8 Inches 1.60 Feet 3.33 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10	1.88	153	333

Perforations:  
Type perforation \_\_\_\_\_  
Size perforation \_\_\_\_\_  
From 2.33 feet to 2.53 T.C. feet  
From 2.89 feet to 3.05 T.C. feet  
From 3.33 feet to 3.13 Factory feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 120 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EDDCO EXPLORATION, INC Contractor  
Address 7780 CURRY RD Contractor  
FALLON, NV  
Nevada contractor's license number 27673  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
Signed Jerald W. Rhinell  
By driller performing actual drilling on site or contractor  
Date 9-2-93

Date started 8-26, 1993  
Date completed 9-2, 1993

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>20</u>		<u>6</u>

93 OCT 22 11:05 AM STATE ENGINEERS OFFICE