

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24323

1. OWNER CHARLES GRANT CONST. ADDRESS AT WELL LOCATION 1694 COYOTE RD.
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION NE 1/4 SE 1/4 Sec 26 T 13 N S R 20 E DOUGLAS County
 PERMIT NO. 23-140-07 EAST VALLEY Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	9	9
SANDY CLAY w/GRAVEL		9	43	34
SAND + GRAVEL		43	54	11
SANDY CLAY		54	68	14
SANDY CLAY w/GRAVEL		68	93	25
SAND + GRAVEL		93	114	21
SANDY CLAY w/GRAVEL		114	177	63
SANDY CLAY		177	192	15
SANDY CLAY w/GRAVEL		192	198	6
SAND		198	214	16
SANDY CLAY		214	221	7
SAND		221	248	27
SANDY CLAY		248	250	2

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 230 feet to 250 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 9-8, 1993
 Date completed 9-11, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>—</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat A. Murray
 By driller performing actual drilling on site or contractor
 Date 9-11-93