

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24310

1. OWNER CONSTRUCTION ZONE ADDRESS AT WELL LOCATION 1909 HORSE BRUSH
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION SW NW SE 1/4 Sec 36 T. 13 N. S. R. 20 E. DOUGLAS County
 PERMIT NO. 23-472-09 WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/COBBLES		0	23	23
SANDY CLAY w/GRAVEL		23	56	33
SANDY CLAY		56	213	157
SANDY CLAY w/GRAVEL		213	305	92
GREY SANDY CLAY		305	406	101
SAND + GRAVEL		406	412	6
SANDY CLAY		412	433	21
CLAY		433	481	48
SANDY CLAY		481	511	30
CLAY		511	518	7
SANDY CLAY		518	585	67
SAND	✓	585	588	3
SANDY CLAY		588	596	8
SAND	✓	596	598	2
SANDY CLAY		598	613	15
SAND	✓	613	617	4
SANDY CLAY		617	620	3

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 620 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 620 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>620</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 580 feet to 620 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 620 feet

9. WATER LEVEL
 Static water level 170 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Mooney
 By driller performing actual drilling on site or contractor
 Date 9-21-93

Date started 9-11, 1993
 Date completed 9-21, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>10+</u>	<u>—</u>	<u>4</u>

SEP 28 AM 11:06
 STATE ENGINEER OFFICE