WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42788
Permit No.
Basin 107

NOTICE OF INTENT NO.

1. OWNER Murrell + Jean Williams
MAILING ADDRESS P.O. Box 47
Wellington Nev 89444

ADDRESS AT WELL LOCATION #23 Upper Colony
Wellington Nev 89444

2. LOCATION NE ¼ SW ¼ Sec 34 T 11 N/S R 23 E Lyon County

PERMIT NO. Issued by Water Resources | Parcel No. 10-361-11 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG Fill + Rock		0	15	15
DG Fill + Rock - Clay		15	23	8
DG Fill + Rock		23	80	57
Clay - DG Fill		80	90	10
DG Fill		90	112	22
DG Fill - Clay		112	123	11
DG Fill - Rock - Clay		123	130	7
DG Fill - Rock	X	130	141	11
DG Fill - Clay		141	149	8
DG Fill - Rock	X	149	240	91
DG - Fill - Clay		240	260	20
DG Fill - Rock	X	260	299	39

'93 OCT 27 A11:25
RECEIVED
STATE ENGINEERS OFFICE

Date started April 22, 1993
Date completed April 30, 1993

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	25	5	1 HRS

8. WELL CONSTRUCTION
Depth Drilled 299 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	186 Feet
7 7/8 Inches	186 Feet	299 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	299

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3 x 6 Rows
From 279 feet to 299 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 299 feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling
Contractor
Address 162 N. ByBee Lane
Contractor
Yerington Nev 89447

Nevada contractor's license number issued by the State Contractor's Board 15646

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed Lg Ogden
By driller performing actual drilling on site or contractor
Date 10-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627