

OFFICE USE ONLY
 Log No. 42793
 Permit No. _____
 Basin 9-108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9145

1. OWNER Ted Lemons ADDRESS AT WELL LOCATION 13 N. Andes
 MAILING ADDRESS 2930 Mark Ridge Dr Yerington Nev 89447
Reno Nev 89509

2. LOCATION SW 1/4 SW 1/4 Sec 9 T. 13 S. R. 26 E. Lyon County _____
 PERMIT NO. 14-591-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness	
Sand - Top Soil		0	5	5	
Clay - Gravel - Rock		5	12	7	
Fill Coarse Sand & Gravel & Rock		12	48	36	
Clay - Sand - Gravel		48	59	11	
Coarse Sand - Gravel		59	94	35	
Coarse Sand - Gravel - Clay		94	110	16	
Fine Sand - Gravel - Coarse Sand - Gravel & Rock	X	110	134	24	
		X	134	158	24

8. WELL CONSTRUCTION
 Depth Drilled 158 Feet Depth Cased 159 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 159 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>71</u>	<u>158</u>

Perforations:
 Type perforation Sawed
 Size perforation 7/32 x 3" x Rows
 From 138 feet to 158 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 158 feet

93 OCT 27 AM 1:25
 RECEIVED
 STATE ENGINEERS OFFICE

Date started 8-23 1993
 Date completed 8-25 1993

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailor</u>	<u>40</u>	<u>5</u>	<u>1/2</u>
<u>Air Lift</u>	<u>70</u>	<u>140' air line</u>	<u>2 HRS</u>

9. WATER LEVEL
 Static water level 4.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Osgden Bros Drilling Contractor
 Address 162 N. Bybee Lane Contractor
Yerington Nev 89447

Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed Jay Osgden
 By driller performing actual drilling on site or contractor
 Date 9-4-93