WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42796
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 19146

1. OWNER G Lazy B Partnership
MAILING ADDRESS Hwy 110 95-A East Yerington NV 89447
ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ SW ¼ Sec. 18 T. 13 N S R. 26 E. Lyon County
PERMIT NO. 59049T (Issued by Water Resources) 14-501-09 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	3	3
Fine to Coarse Sand		3	12	9
Brown Clay		12	15	3
Coarse Sand + Gravel		15	17	2
Blue-Gray Clay + Brown Clay		17	18	1
Coarse Sand - Blue-Gray Clay		18	23	5
Blue-Gray Clay		23	25	2
Brown Clay		25	30	5
Fine Sand - Coarse Sand		30	40	10
Brown Clay - Gravel		40	48	8
Coarse Sand - Gravel		48	53	5
Brown Clay - Gravel		53	72	19
Brown Clay Stratas - Gravel		72	90	18
Coarse Sand - Gravel		90	108	18
Gravel - Clay		108	130	22
Fine to Coarse Sand - Gravel		130	142	12
DG - Gravel - Clay Stratas	X	142	164	22

Date started 9-22, 19 93
Date completed 9-27, 19 93

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	25	3	½ Hrs
Air Lift	60	140' air line	2 Hrs

8. WELL CONSTRUCTION
Depth Drilled 164 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¾	0	164

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	+1	164

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 8 Rows
From 144 feet to 164 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 164 feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Zay Ogden (By driller performing actual drilling on site or contractor)
Date 10-13-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627