

OFFICE USE ONLY
 Log No. 12797
 Permit No. _____
 Basin 9-108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Don + Bella French ADDRESS AT WELL LOCATION #3 Farrell Lane
 MAILING ADDRESS #3 Farrell Lane Yerington Nev 89442
 2. LOCATION NE 1/4 NE 1/4 Sec 9 T 14 N R 25 E Lyon County
 PERMIT NO. 14-191-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	5	5
Coarse Sand + Gravel		5	23	18
Coarse Sand + Blue Clay		23	29	6
Coarse Sand + Gravel		29	40	11
Coarse Sand - Gravel - Brown Clay		40	56	16
Coarse Sand - Gravel - Blue Clay		56	61	5
Coarse Sand - Gravel - Brown Clay		61	70	9
Brown Clay - Gravel		70	81	11
Coarse Sand - Gravel	X	81		

193 OCT 27 AM 11:25
 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 101 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>100</u>

Perforations:
 Type perforation Sawed
 Size perforation 3/32 x 3" x 6 Rows
 From 80 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Fair - Iron

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. By Dee Lane Contractor
Yerington Nev 89442
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Jay Ogden
 By driller performing actual drilling on site or contractor
 Date 9-20-93

Date started Sept 17 1993
 Date completed Sept 20 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Bailer	<u>25</u>	<u>3</u>	<u>1/2 Hrs</u>
80' air line	<u>100</u>		<u>1 Hr</u>