

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Edward Hall ADDRESS AT WELL LOCATION 567 Pete Hendricks Rd
 MAILING ADDRESS 567 Pete Hendricks Rd
Yerington Nev 89447
 2. LOCATION SE 1/4 SE 1/4 Sec. 34 T. 14 N. S. R. 26 E. Lyon County
 PERMIT NO. 14-381-24 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Coarse Sand-				
Gravel-Rock Fill		5	46	41
Coarse Sand-				
Gravel-Rock-Clay		46	70	24
Coarse Sand-Gravel-				
Clay		70	76	6
Coarse Sand-Clay		76	86	10
Clay-Fine Sand		86	98	12
Fine to Coarse Sand		98	142	44
Clay-Sand		142	146	4
Coarse Sand-				
Gravel-Clay		146	163	17
Clay-Sand		163	180	17
Coarse Sand-				
Gravel		180	201	21

8. WELL CONSTRUCTION
 Depth Drilled 201 Feet Depth Cased 202 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 201 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>±1</u>	<u>201</u>

Perforations:
 Type perforation Sawed
 Size perforation 3/32 x 3 x 6 Rows
 From 181 feet to 201 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 201 feet

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Good °F Quality Good

Date started June 15, 1993
 Date completed June 18, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>25</u>	<u>5</u>	<u>1/2 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Cyden Bros Drilling Contractor
 Address 162 N By Bee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Lang Colon
 _____ driller performing actual drilling on site or contractor
 Date 10-23-93

93 OCT 27 AM 1:25
 RECEIVED
 STATE ENGINEERS OFFICE