

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 42816  
 Permit No. \_\_\_\_\_  
 Basin 2-302

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4675

1. OWNER RIO KING RANCH COMPANY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. BOX 122 KINGS RIVER KINGS RIVER VALLEY, KINGS RIVER, NV.  
VALLEY- OROVADA, NV 89425

2. LOCATION NW 1/4 SE 1/4 Sec. 14 T. 45N N/S R. 33 E HUMBOLDT County  
 PERMIT NO. W389 Issued by Water Resources | NONE Parcel No. | NONE Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  ~~TEST WELL~~

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	8	8
course sand		8	30	22
sandy clay		30	40	10
sand		40	50	10
sandy clay & silty clay		50	80	30
silty clay		80	98	18
sand & gravel		98	134	36
med.brn sandy clay		134	150	16
course sand		150	187	37
med. brn silty clay		187	200	13
course sand		200	210	10
sand and sandy clay		210	290	80
med.to crs sand		290	308	18
silty clay		308	322	14
med to crs sand		322	337	15
sandy clay		337	355	18
med. to course sand		355	385	30
med.brn sandy clay		385	440	55
med. to crs sand		440	480	40
sand and gravel		480	520	40
med to crs sand		520	530	10
crs sand		530	600	70
ABANDONMENT: this well is abandoned.				
5/8" X4" perma plug		600	50	
concrete		50	surface	

8. WELL CONSTRUCTION  
 Depth Drilled 600 Feet Depth Cased 0 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 6.00 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
none				

Perforations:  
 Type perforation none  
 Size perforation \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PETE COPE DRILLING CO., INC. Contractor  
 Address 6505 W. CHINDEN Contractor  
MERIDIAN, IDAHO 83642

Nevada contractor's license number issued by the State Contractor's Board 13443  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1484  
 Signed Joseph Cope By driller performing actual drilling on site or contractor  
 Date 10/28/92

Date started 9-24, 1992  
 Date completed 9-27, 1992

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
NONE			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	