WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42825
Permit No.
Basin 4-45

NOTICE OF INTENT NO. 25382

1. OWNER STEVE BEQUETTE
MAILING ADDRESS 170 Pleasant Valley Estates Unit 14
Elko, NV 89801

ADDRESS AT WELL LOCATION East side of Rabbit Ears Road between two Bottle Bar Lane and Sum Mountain Lane

2. LOCATION NW ¼ NE ¼ Sec. 26 T 33 N/S R 57 E Elko County
PERMIT NO. Issued by Water Resources
23-022-04 Parcel No.
Pleasant Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Clay, boulders & gravel		2	20	18
Brown siltstone		20	120	100
Sand & some gravel	X	120	200	80

'93 OCT 13 AM 11:49
STATE ENGINEER'S OFFICE

Date started September 20, 1993
Date completed September 21, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		10

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+ 1-1/2	175
4		.188	165	185

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 155 feet to 175 feet
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 175 feet

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. Contractor
Address P.O. BOX *** 850 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-7-1993

(Rev. 3-91)
DGGPGGS by LOG 125924

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627