WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42831
Permit No.
Basin 41-48

NOTICE OF INTENT NO. 24267

1. OWNER Don Farmer
MAILING ADDRESS P.O. Box 1324
Elko, NV 89803

ADDRESS AT WELL LOCATION East side of Pioneer Way about 1/4 mile from end of road.

2. LOCATION SE ¼ NW ¼ Sec. 15 T 33 N/S R 55 E Elko County
PERMIT NO. (Issued by Water Resources) 77-003-16 (Parcel No.) Western Hills (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown Clay		1	7	6
Brown Clay & Gravel		7	18	11
Brown Clay		18	63	45
Bluue Shale		63	68	5
Brown Siltstone		68	100	32
Brown & Black Silicified Material	X	100	170	70
White & Black Silicified Material	X	170	220	50

'93 NOV 25 P1:54
STATE ENGINEER

Date started 10-14, 1993
Date completed 10-21, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		8

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	*1½	220

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O.Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dave Hersh (By driller performing actual drilling on site or contractor)
Date 10-22-1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627